



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 7/17/09

Code 32.5

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

| | | |
|---|---------------------|-----------------------|
| Code Title INDIANA RESIDENTIAL CODE | | Edition 2009 |
| Section number and title R311.7.4.1 AND R311.7.4.2 | | Page 60 |
| Proponent JOHN R. WEESNER | Title CONSULTANT | |
| Address P.O. BOX 876 | | Phone 765-242-5503 |
| PROPOSED CODE CHANGE (Check One) | | |
| Change to read as follows <input type="checkbox"/> Add to read as follows <input checked="" type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution | | |
| IN THE FIRST SENTENCE OF SECTION R311.7.4.1 DELETE “73/4 INCHES (196mm)” AND SUBSITUTE “81/4 INCHES (210mm)” | | |
| IN THE FIRST SENTENCE OF SECTION R311.7.4.2 DELETE “10 INCHES (254mm)” AND SUBSTITUTE “9 INCHES (229mm)” | | |
| REASON AND FISCAL IMPACT | | |
| THIS BRINGS THE CURRENT AMENDMENT FORWARD. IT HAS BEEN IN THE CODE FOR SOMETIME WITH NO KNOWN PROBLEMS | | |
| THERE WILL BE NO ADDED COST | | |
| REVIEW RECOMMENDATION | | |
| Approve | | |
| Disapprove | | |
| Approve as amended | | |
| Further Study | | |